

Annexure C

PROFORMA FOR SAFE DRINKING WATER AND SANITARY CONDITION CERTIFICATE

NO. : 404/2024

Dated : 30/12/2024

It is certified that an inspection team headed by Shri, P.T.Jagtap, Sub Divisional Engineer, Maharashtra Jeevan Pradhikaran, Rural Sub Division, Baramati (Name of Officer with designation) from Agricultural Development Trusts, Krishi Vigyna Kendra, (Approved by Indian Council of Agricultural Research, Delhi) Malegaon Khurd, Tal. Baramati inspected the Vidya Pratishthan's English Medium School (CBSE), Vidyanagari, Baramati' on 07.12.2024 and on the basis of Water Test Report (attached) bearing No.211 Dated 07.12.2024 of (Lab) certified that the 'Vidya Pratishthan's English Medium School (CBSE), Vidyanagari, Baramati' has safe drinking water facilities for students and members of staff of the instituton. School is also maintains the hygenic sanitation condition in the school building and the campus as per norms prescribed by the Central/State/U.T. Govt.

This certificate is valid till 30.12.2025

Signature with seal : _____



Name : Pradip Tanajis Jagtap

Designation : sub division Engin.

Name & Address of the Office/Department

Sub-Divisional Engineer
Maharashtra Jeevan Pradhikaran
Urban Sub-Division, Baramati

To,

Principal,

Vidya Pratishthan's English Medium School (CBSE),

Vidyanagari, Baramati

Dist. Pune 413133

Drinking Water Report

Name of Person:- Vidya prtishthan English Medium School Receipt No:- Report No:- 211
Village:- MIDC
Tal:- Baramati Dist:- Pune Date of Submission of Sample:- 07/12/2024 Inward No:- 211
Name of Source:-


Drinking Water Sample Analysis Report

Sr.No.	Parameters	Unit	Readings	Range BIS (IS:10500:2012)
1	pH	-	7.47	6.5 to 8.5
2	Colour	Hazen	Colour less	5.0
3	Turbidity	NTU	0.5	5.0
4	Odour	-	Unobjectionable	Unobjectionable
5	Taste	-	Agreeable	Agreeable / Unagreeable
6	Total dissolved solids mg/L	ppm	26.24	500
7	Total hardness as CaCO ₃ mg/L	ppm	60.05	300
8	Calcium as Ca mg/L	ppm	16.03	75
9	Magnesium as Mg mg/L	ppm	4.86	30
10	Chloride as Cl mg/L	ppm	60.00	250
11	Sulphate as SO ₄ mg/L	ppm	10.52	200
12	Nitrate as NO ₃ mg/L	ppm	5.49	45
13	Iron as Fe mg/L	ppm	0.01	0.3
14	Fluoride as F mg/L	ppm	0.18	1.00
15	Manganese as Mn mg/L	ppm	0.02	0.1
16	Zinc as Zn mg/L	ppm	0.03	5.00
17	Copper as Cu mg/L	ppm	0.01	0.05
18	Residual free chlorine mg/L	ppm	0.18	0.2
19	Alkalinity mg/L	ppm	40.00	200
20	Sodium (Na) mg/l	ppm	3.99	200
21	Total Coliform MPN/100 Cm ³	Coliform	2.00	MPN (per 100 ml)

Remark: - Suitable/ ~~unsuitable~~ for drinking Purpose directly.
Recommendation: - Use Uv/Uf/Ro/TDS Controller for treatment
Note: - This report is not used for court matter.


प्रद्युम्न

मृदा, पान, देठ, पाणी चिकित्सालय
कृषि विज्ञान केंद्र बaramati, जि. पुणे



Agricultural Development Trust's
Krishi Vigyan Kendra

Malegaon Khurd, Tal- Baramati, Dist- Pune

Telefax- (02112)255427, 255207

Email: kvkbmt@yahoo.com Website: kvkbaramati .com



Drinking Water Report

Name of Person:- Vidya prtishthan English Medium School Receipt No:- Report No: - 211

Village: - MIDC

Tal:- Baramati Dist:- Pune Date of Submission of Sample:- 07/12/2024 Inward No:- 211

Name of Source: -

Drinking Water Sample Analysis Report

Sr.No.	Parameters	Unit	Readings	Range BIS (IS:10500:2012)
1	pH	-	7.47	6.5 to 8.5
2	Colour	Hazen	Colour less	5.0
3	Turbidity	NTU	0.5	5.0
4	Odour	-	Unobjectionable	Unobjectionable
5	Taste	-	Agreeable	Agreeable / Unagreeable
6	Total dissolved solids mg/L	ppm	26.24	500
7	Total hardness as CaCO ₃ mg/L	ppm	60.05	300
8	Calcium as Ca mg/L	ppm	16.03	75
9	Magnesium as Mg mg/L	ppm	4.86	30
10	Chloride as Cl mg/L	ppm	60.00	250
11	Sulphate as SO ₄ mg/L	ppm	10.52	200
12	Nitrate as NO ₃ mg/L	ppm	5.49	45
13	Iron as Fe mg/L	ppm	0.01	0.3
14	Fluoride as F mg/L	ppm	0.18	1.00
15	Manganese as Mn mg/L	ppm	0.02	0.1
16	Zinc as Zn mg/L	ppm	0.03	5.00
17	Copper as Cu mg/L	ppm	0.01	0.05
18	Residual free chlorine mg/L	ppm	0.18	0.2
19	Alkalinity mg/L	ppm	40.00	200
20	Sodium (Na) mg/l	ppm	3.99	200
21	Total Coliform MPN/100 Cm ³	Coliform	2.00	MPN (per 100 ml)

Remark: - Suitable/ ~~unsuitable~~ for drinking Purpose directly.

Recommendation: - Use Uv/Uf/Ro/TDS Controller for treatment

Note: - This report is not used for court matter.

Handwritten Signature
प्रमुख

मृदा, पान, देठ, पाणी चिकित्सालय
कृषि विज्ञान केंद्र बारामती, जि. पुणे